



Identification sign

Product information

Application

Used to form a bulkhead for cable wall and ceiling penetration, against the effects of fire for a period of 90 minutes in accordance with DIN 4102-9 (fire resistance class S90).

Article No.	Bulkhead	Application	Info
300 469	Fire protection brick Pyrosys TS90	For provision of a square S90 bulkhead in ceilings and walls in accordance with DIN 4102-9	Packaging comprises 20 pieces dry and dust-free assembly, problem free installation Volume app. 220 x 120 x 60mm
300 477	Fire protection block Pyrosys TS90	For closing gaps and spandrels and wall soffits	Set consists of 12 cartridges 310ml cartridge, white
300 478	Identification sign Fire protection plug Fire protection brick	For permanent identification of a cable fire wall, DIN 4102-9	Set consists of 10 identification signs